

RFI Q & A may 25 2022

Amanda electrical responses are as follows:

- 1.) The one-line doesn't show any electrical metering equipment. Does there need to be? Or does the airport own the utility and just bills the owners direct? **Yes, there will be a meter and CT but we are waiting on HCE coordination to determine locations. Future drawing sets will show more detail as available.**

- 2.) The site utility plan notes the transformer is 410' away from the building, is this accurate? ~~This is a preliminary location. We are still waiting the final design from Holy Cross Energy to see where they install the primary with the transformers.~~ **The 410' is the distance to the end of the primary line extension currently in progress, it is not the transformer location. We anticipate that HCE primary underground will ultimately be extended to the lease line. The responsibility for, and timing of, that extension are unclear at this point.**