


PROJECT # 23364

DEPARTMENT OF TRANSPORTATION

SAP BUILDING NO # 1000/3/381

<u>DATE</u>	<u>No.</u>	<u>DESCRIPTION</u>
06/26/2020	1	70% CONSTRUCTION DOCUMENTS
08/03/2020	2	95% CONSTRUCTION DOCUMENTS
08/07/2020	3	99% CODE REVIEW
09/23/2020	4	100% BID SET

Z O



REMC

81648

303-512-5550

CONSTRUCTION PLANS RANGELY OFFIC 2829 E SHALE DRIVE RANGELY, COLORADO 8

DRAWN BY: RL

CDOT PROJECT NO. 23364 SAP BUILDING # 1000/3/381

an Of ent


SCHED \leq Ш \square GENERAL

2829 E SHALE DRIVE RANGELY, COLORADO RANG

DRAWN BY: RL

CDOT PROJECT NO. 23364 SAP BUILDING # 1000/3/381

A3.0



1 CEILING MOUNTED EXHAUST FAN DETAIL (M0.0) SCALE: NTS

MECHANICAL NOTES

A. ALL WORK SHALL BE IN ACCORDANCE WITH SMACNA STANDARDS AND SPECIFICATIONS, AND LOCAL AUTHORITY

DRAWINGS DUE TO CONFLICTS, AS LONG AS FUNCTION AND/OR APPEARANCE ARE NOT AFFECTED.

E. CONTRACTOR SHALL REVIEW THESE DOCUMENTS CAREFULLY. CONTRACTOR SHALL CONTACT CDOT REPRESENTATIVE FOR RESOLUTION OF ANY DISCREPANCIES, OMISSIONS, OR CLARIFICATIONS, BEFORE BID DATE. IN THE EVENT THAT AN INTERPRETATION OF BID DOCUMENTS IS NECESSARY AFTER THE BID DATE, THE DECISION OF CDOT

F. PRODUCT DELIVERY, STORAGE, AND HANDLING: PROVIDE EQUIPMENT AND PERSONNEL TO HANDLE PRODUCTS BY METHODS TO PREVENT DAMAGE. PROMPTLY INSPECT SHIPMENTS TO ENSURE THAT PRODUCTS ARE UNDAMAGED.

G. THE CONTRACTOR IS RESPONSIBLE FOR THE COSTS OF ALL CHANGE ORDERS, WHICH THE OWNER AND ENGINEER HAVE NOT APPROVED IN WRITING PRIOR TO THE EXECUTION OF THE ASSOCIATED WORK.

H. IN THE CASE OF A CONFLICT, UNLESS OTHERWISE NOTED, KEYNOTES ON MECHANICAL PLANS SHALL SUPERCEDE ANY

I. CONTRACTOR SHALL COORDINATE WORK WITH OTHER TRADES AND NOTIFY CDOT REPRESENTATIVE IF ANY CONFLICTS

J. THERMOSTAT LOCATIONS AND HEIGHTS TO BE 48" TO MATCH LIGHT SWITCH HEIGHTS. CONTRACTOR TO CALIBRATE ALL

K. MECHANICAL CONTRACTOR TO CHECK OPERATION AND CONDITION OF ALL EXISTING MECHANICAL EQUIPMENT WITHIN THE CONFINES OF THIS SPACE AND PREPARE A WRITTEN LIST OF ANY DEFICIENCIES IN EQUIPMENT OPERATION OR

THROUGH-WALL AIR CONDITIONER	

GENERAL			COOLING PERFORMANCE AT SEA LEVEL					ELECTRICAL					PHYSICAL				NOTES
TAG	MANUFACTURER	MODEL	CAPACITY	POWER	AMPS	AIRFLOW	EER	VOLTAGE	PHASE	FREQ.	MOCP	RLA	WIDTH	HEIGHT	DEPTH	WEIGHT	
			[BTU]	[W]	[A]	[CFM]		[V]		[HZ]	[A]	[A]	[IN]	[IN]	[IN]	[LBS]	
AC-1	LG	LT1216CER	11,800	990	9.3	265	10.6	115	1	60	15	9.3	24	14	20	82	1,2,3
NOTES:																	

1. PROVIDE UNIT WITH TRIM KIT AND WALL SLEEVE WITH STAMPED ALUMINUM GRILLE

2. ENSURE UNIT IS SHIMMED WITHIN WALL SLEEVE, TILTED SLIGHTLY SO CONDENSATE DRAINS TO EXTERIOR OF BUILDING

3. PROVIDE WITH REMOTE CONTOLLER AND WALL MOUNTED REMOTE HOLDER

FAN SCHEDULE

GENERAL						PERFORMA	NCE (@ 5,300	FT)			ELECTRICA	L		PHYSICA	L			NOTES
TAG	MANUFACTURER	MODEL	LOCATION	SERVICE	TYPE	AIRFLOW	ESP	SPEED	POWER	SOUND		Ø FR	EQ. FL	LENGT	H WIDTH	HEIGHT	WEIGHT	
						[CFM]	[IN. W.C.]	[RPM]	[W]	[SONES]	[V]	[⊦	IZ] [A	[IN]	[IN]	[IN]	[LBS]	
EF-1	GREENHECK	SP-B90	102	BATHROOM EXHAUST	CEILING	85	0.13	700	17	0.9	115	1 6	0.6	5 14	12	7	10	1,2,3
NOTES:																		•

- 1. PROVIDE WITH TIMECLOCK, COORDINATE SCHEDULE WITH OWNER TO RUN DURING OCCUPIED HOURS.
- 2. PROVIDE WITH VENT HOOD FOR EXHAUST OUTLET IN WALL (HERCULES INDUSTRIES SKU# 6GDV OR APPROVED EQUAL)
- 3. CEILING MOUNTED

ELECTRIC HEAT SCI	HEDULE

					_								
NERAL					ELECTRICAL				PHYSICAL				
TAG	MANUFACTURER	MODEL	LOCATION	ARRANGEMENT	VOLTAGE	PHASE	FREQ	POWER	DEPTH	WIDTH	HEIGHT	WEIGHT	REMARKS
					[V]		[HZ]	[KW]	[IN]	[IN]	[IN]	[LBS]	
BB-1	QMARK	2514W	101	BASEBOARD	120	1	60	1,000	3	48	6.75	10	1,2,3
BB-2	QMARK	2513W	102	BASEBOARD	120	1	60	750	3	36	6.75	8	1,2,3

1. PROVIDE WITH SEPARATE LINE VOLTAGE THERMOSTAT

2. PROVIDE WITH MANUFACTURER'S MOUNTING BRACKET AND HARDWARE

3. PROVIDE WITH NECESSARY EQUIPMENT TO ALLOW WALL MOUNTED ISTALLATION.

NATURAL VENTILATION CALCULATION ((CALCULATIONS BASED ON IMC 402.2)

·		,		
ROOM NAME	ROOM#	SQUARE FEET	OPERABLE OPENING	OPERABLE OPENING
			REQUIRED [SF]	PROVIDED [SF]
OFFICE	101	133	5.3	8
RESTROOM	102	74	3.0	4

HAVING JURISDICTION.

B. THESE DRAWINGS ARE DIAGRAMMATIC IN NATURE AND NOT INTENDED TO SHOW ALL TRANSITIONS, OFFSETS, ETC. CONTRACTOR SHALL FIELD VERIFY EXISTING CONDITIONS AND PROVIDE ALL NECESSARY FITTINGS TO COMPLETE THE INTENT OF THE DRAWINGS. ANY DISCREPANCIES BETWEEN DRAWINGS AND FIELD CONDITIONS SHALL BE REPORTED TO THE ENGINEER FOR RESOLUTION. CONTRACTOR MAY LOCATE MECHANICAL EQUIPMENT DIFFERENTLY THAN SHOWN ON

C. COORDINATE SPACE REQUIREMENTS, SUPPORTS, AND INSTALLATION OF MECHANICAL WORK, WHICH ARE INDICATED DIAGRAMMATICALLY ON THE DRAWINGS. FOLLOW ROUTING SHOWN FOR PIPES AND DUCTS AS CLOSELY AS PRACTICABLE; PLACE RUNS PARALLEL WITH LINES OF BUILDING. UTILIZE SPACES EFFICIENTLY TO MAXIMIZE ACCESSIBILITY FOR OTHER INSTALLATIONS, FOR MAINTENANCE, AND FOR REPAIRS.

D. COMPLY WITH MANUFACTURER'S INSTRUCTIONS INCLUDING EACH STEP IN SEQUENCE. SHOULD MANUFACTURERS' INSTRUCTIONS CONFLICT WITH THE DRAWINGS REQUEST CLARIFICATION FROM THE ENGINEER BEFORE PROCEEDING.

SHALL BE FINAL AND BINDING.

STORE AND PROTECT PRODUCTS IN ACCORDANCE WITH MANUFACTURERS' INSTRUCTIONS.

GENERAL NOTES ON THE PLANS.

THERMOSTATS SHOWN ON THIS PLAN.

CONDITION. LIST SHALL BE SUBMITTED TO PROPERTY MANAGER TWO WEEKS AFTER THE AWARD OF THE CONTRACT.

L. THERMOSTAT CONTROL LINES SHALL BE SUPPORTED AT INTERVALS NOT TO EXCEED 4'0".

M. ALL PIPE AND DUCT PENETRATIONS THOUGH RATED WALLS SHALL BE SEALED PER 2018 IBC.





REGION 3 2829 EAST 3 RANGELY,

DRAWN BY: ASF

DATE:

CDOT PROJECT NO. 17179

9/23/2020

Designer/Contractor: 360 Engineering 751 Pine Ridge Road #360 Golden, CO 80403 3039402050

Mechanical Systems List Quantity System Type & Description 1 HVAC System 2 (Single Zone):

Cooling: 1 each - Packaged Terminal Unit, Capacity = 12 kBtu/h, Air-Cooled Condenser, No Economizer, Economizer exception: Low Capacity Residential

Proposed Efficiency = 10.60 EER, Required Efficiency: 10.40 EER Fan System: FAN SYSTEM 1 -- Compliance (Motor nameplate HP method) : Passes

Fans: FAN 1 Supply, Constant Volume, 265 CFM, 0.1 motor nameplate hp, 0.0 fan efficiency grade 1 HVAC System 3 (Single Zone): Heating: 1 each - Radiant Heater, Electric, Capacity = 3 kBtu/h No minimum efficiency requirement applies
Fan System: None

1 HVAC System 3 copy 1 (Single Zone): Heating: 1 each - Radiant Heater, Electric, Capacity = 3 kBtu/h No minimum efficiency requirement applies Fan System: None

Mechanical Compliance Statement

Compliance Statement: The proposed mechanical alteration project represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed mechanical systems have been designed to meet the 2018 IECC requirements in COMcheck Version 4.1.2.2 and to comply with any applicable mandatory requirements listed in the Inspection Checklist. 8/7/2020 Joe Wittenberg - Project Manager Name - Title

Data filename: Z:\2020\20-047A - CDOT Rangely\ENG\Rangeley Comcheck.cck

Report date: 08/07/20 Page 2 of 12

Section #	Plan Review	Complies?	Comments/Assumptions
& Req.ID C103.2 [PR2] ¹		☐Complies ☐Does Not ☐Not Observable	
	systems and equipment and document where exceptions to the standard are claimed. Load calculations per acceptable engineering standards and handbooks.	□Not Applicable	
Addition	al Comments/Assumptions:		
	Taluncia de la companya della companya della companya de la companya de la companya della compan		
	1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	
Project Title	e: me: Z:\2020\20-047A - CDOT Rangely	\ENG\Rangeley Comcheck.cck	Report date: 08/07/ Page 3 of

▲ COM*check* Software Version 4.1.2.2

Inspection Checklist

Requirements: 74.0% were addressed directly in the COMcheck software

Energy Code: 2018 IECC

Section # & Req.ID	Footing / Foundation Inspection	Complies?	Comments/	Assumptions		
C403.12.2	Snow/ice melting system and freeze protection systems have sensors and	□Complies □Does Not	Exception: Requirement does	not apply.		
C403.12.3 [FO9] ³	controls configured to limit service for pavement temperature and outdoor temperature. future connection to	□Not Observable □Not Applicable				
Additiona	controls. al Comments/Assumptions:	1	 			
- Carrione	ar comments, Assumptions:					
	1 High Impact (Tier 1)	2 Medium Impa	act (Tier 2) 3 Low Impact	(Tier 3)		
Project Title				Report date:	08/07/2	20
	ne: Z:\2020\20-047A - CDOT Rangely\E	ENG\Rangeley Com	check.cck	Page	4 of 3	

Section #	Plumbing Rough-In Inspection	Complies?	Comments/Assumptions
& Req.ID	Figure Rough-III Inspection	complies?	Comments/Assumptions
C404.5, C404.5.1,	Heated water supply piping conforms to pipe length and volume	☐Complies ☐Does Not	Exception: Requirement does not apply.
C404.5.2	requirements. Refer to section details.	□Not Observable	
[PL6] ³		☐Not Applicable	
C404.5, C404.5.1,	Heated water supply piping conforms to pipe length and volume	☐Complies ☐Does Not	Exception: Requirement does not apply.
C404.5.2	requirements. Refer to section details.	□Not Observable	
PL6] ³		□Not Applicable	
C404.5, C404.5.1,	Heated water supply piping conforms	Complies	Exception: Requirement does not apply.
C404.5.1,	to pipe length and volume requirements. Refer to section details.	□Does Not □Not Observable	
PL6] ³		□Not Observable □Not Applicable	
C404.6.3	Pumps that circulate water between a	Complies	Exception: Requirement does not apply.
[PL7] ³	heater and storage tank have controls that limit operation from startup to		
	<= 5 minutes after end of heating cycle.	□Not Observable □Not Applicable	
C404.6.3	Pumps that circulate water between a	□Complies	Exception: Requirement does not apply.
[PL7] ³	heater and storage tank have controls that limit operation from startup to	□Does Not □Not Observable	
	<= 5 minutes after end of heating cycle.	□Not Observable □Not Applicable	
C404.6.3 [PL7] ³	Pumps that circulate water between a heater and storage tank have controls	□Complies	Exception: Requirement does not apply.
	that limit operation from startup to	□Not Observable	
С	<= 5 minutes after end of heating cycle.	□Not Applicable	
2404.7 PL8] ³	Demand recirculation water systems	□Complies □Does Not	Exception: Requirement does not apply.
i LOJ	upon receiving a signal from the	□Not Observable	
	action of a user of a fixture or appliance and limits the temperature	□Not Applicable	
	of the water entering the cold-water piping to 104°F.		
C404 <u>.</u> 7	Demand recirculation water systems	Complies	Exception: Requirement does not apply.
PL8] ³	have controls that start the pump upon receiving a signal from the	□Does Not	
	action of a user of a fixture or	□Not Observable □Not Applicable	
	appliance and limits the temperature of the water entering the cold-water	Applicable	
C404.7	piping to 104°F.	☐Complies	Exception: Requirement does not apply.
[PL8] ³	Demand recirculation water systems have controls that start the pump	□Does Not	Exception: Requirement does not apply.
	upon receiving a signal from the action of a user of a fixture or	□Not Observable	
	appliance and limits the temperature	□Not Applicable	
	of the water entering the cold-water piping to 104°F.		
dditiona	al Comments/Assumptions:		
	1 High large of /Time 4 V	2 Modilina II	act (Tion 2)
	1 High Impact (Tier 1)	2 Medium Imp	
roject Title	2:		Report date: 08/07/20

Page 5 of 12


Report date: 08/07/20

Page 10 of 12

Project Title:

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C402.2.6 [ME41] ³	Thermally ineffective panel surfaces of sensible heating panels have insulation >= R-3.5.	□Does Not	Exception: Requirement does not apply.
	N S S	□Not Observable □Not Applicable	
[ME61] ²	HVAC piping insulation insulated in accordance with Table C403.11.3.	□Complies □Does Not	Exception: Requirement does not apply.
	Insulation exposed to weather is protected from damage and is provided with shielding from solar radiation.	□Not Observable □Not Applicable	
C403.11.3 [ME61] ²	HVAC piping insulation insulated in accordance with Table C403.11.3.	□Complies □Does Not	Exception: Requirement does not apply.
	Insulation exposed to weather is protected from damage and is provided with shielding from solar radiation.	□Not Observable □Not Applicable	
C403.8.1 [ME65] ³	HVAC fan systems at design conditions do not exceed allowable	□Complies □Does Not	Exception: Requirement does not apply.
	fan system motor nameplate hp or fan system bhp.	□Not Observable □Not Applicable	See the Mechanical Systems list for values.
C403.8.1 [ME65] ³	HVAC fan systems at design conditions do not exceed allowable	□Complies □Does Not	Exception: Requirement does not apply.
	fan system motor nameplate hp or fan system bhp.	□Not Observable □Not Applicable	See the Mechanical Systems list for values.
C403.8.3 [ME117] ²	Fans have efficiency grade (FEG) >= 67. The total efficiency of the fan at	□Complies □Does Not	Requirement will be met.
	the design point of operation <= 15% of maximum total efficiency of the fan.	□Not Observable □Not Applicable	
C403.8.3 [ME117] ²	Fans have efficiency grade (FEG) >= 67. The total efficiency of the fan at	□Complies □Does Not	Requirement will be met.
	the design point of operation <= 15% of maximum total efficiency of the fan.	□Not Observable □Not Applicable	
C403.8.4 [ME142] ²	Motors for fans that are not less than 1/12 hp and less than 1 hp are	□Complies □Does Not	Requirement will be met.
	electronically commutated motors or have a minimum motor efficiency of 70 percent. These motors have the means to adjust motor speed.	□Not Observable □Not Applicable	
C403.8.5 [ME143] ²	Each DX cooling system > 65 kBtu and chiller water/evaporative cooling	□Complies □Does Not	Requirement will be met.
	system with fans > 1/4 hp are designed to vary the indoor fan airflow as a function of load and comply with detailed requirements of this section.	□Not Observable □Not Applicable	
C403.12.1 [ME71] ²	envelope are radiant heat systems	□Complies □Does Not	Exception: Requirement does not apply.
	controlled by an occupancy sensing device or timer switch.	□Not Observable □Not Applicable	
C403.2.3 [ME55] ²	HVAC equipment efficiency verified.	□Complies □Does Not	See the Mechanical Systems list for values.
		□Not Observable □Not Applicable	
C403.2.3 [ME73] ³	PTAC and PTHP with sleeves 16 in. by 42 in. labeled for replacement only as per Footnote b to Table C403.2.3(3).	□Complies □Does Not	
	per roomote a to rable C403.2.3(3).	□Not Observable □Not Applicable	
	1 High Impact (Tier 1)	2 Medium Imp	act (Tier 2) 3 Low Impact (Tier 3)
Project Title		NC\Pangalay C	Report date: 08/07/20
vata illena	me: Z:\2020\20-047A - CDOT Rangely\E	ing kangeley com	check.cck Page 6 of 12

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.2.2 [ME59] ¹	Natural or mechanical ventilation is provided in accordance with International Mechanical Code Chapter 4. Mechanical ventilation has capability to reduce outdoor air supply to minimum per IMC Chapter 4.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.7.1 [ME59] ¹	Demand control ventilation provided for spaces >500 ft2 and >25 people/1000 ft2 occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow >3,000 cfm.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	Exception: Requirement does not apply.
C403.7.2 [ME115] ³	Enclosed parking garage ventilation has automatic contaminant detection and capacity to stage or modulate fans to 50% or less of design capacity.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C403.7.6 [ME141] ³	HVAC systems serving guestrooms in Group R-1 buildings with > 50 guestrooms: Each guestroom is provided with controls that automatically manage temperature setpoint and ventilation (see sections C403.7.6.1 and C403.7.6.2).	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C403.7.4 [ME57] ¹	Exhaust air energy recovery on systems meeting Table C403.7.4(1) and C403.7.4(2).	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C403.7.5 [ME116] ³	Kitchen exhaust systems comply with replacement air and conditioned supply air limitations, and satisfy hood rating requirements and maximum exhaust rate criteria.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
,	HVAC ducts and plenums insulated in accordance with C403.11.1 and constructed in accordance with C403.11.2, verification may need to occur during Foundation Inspection.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.4.1. 4 [ME63] ²	Heating for vestibules and air curtains with integral heating include automatic controls that shut off the heating system when outdoor air temperatures > 45F. Vestibule heating and cooling systems controlled by a thermostat in the vestibule with heating setpoint <= 60F and cooling setpoint >= 80F.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C403.3.3 [ME35] ¹	Hot gas bypass limited to: <=240 kBtu/h - 50% >240 kBtu/h - 25%	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C408.2.2. 1 [ME53] ³	Air outlets and zone terminal devices have means for air balancing.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
	1 High Impact (Tier 1)	2 Medium Impa	act (Tier 2) 3 Low Impact (Tier 3)



₹ Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
2405.6	Low-voltage dry-type distribution	□Complies □	
EL26] ²	electric transformers meet the	□Does Not	
	minimum efficiency requirements of Table C405.6.	□Not Observable	
		□Not Applicable	
(405.7 EL27] ²		□Complies □Does Not	
LLZ/j	CAOE 7/1) II I CAOE 7/4)	□Not Observable	
		□Not Observable □Not Applicable	
	program or the equipment efficiency		
	ratings shall be provided by motor manufacturer (where certification		
	programs do not exist).		
405.8.2,		☐Complies	
405.8.2.	with ASME A17.1/CSA B44 and have automatic controls configured to	□Does Not	
EL28] ²	reduce speed to the minimum	□Not Observable	
	permitted speed in accordance with ASME A17.1/CSA B44 or applicable	□Not Applicable	
	local code when not conveying		
2405.9	passengers. Total voltage drop across the	□Complies	
EL29] ²	combination of feeders and branch	Does Not	
	circuits <= 5%.	□Not Observable	
		□Not Applicable	
	1 High Impact (Tier 1)	2 Medium Impac	t (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C303.3, C408.2.5. 3 [FI8] ³	Furnished O&M manuals for HVAC systems within 90 days of system acceptance.	□Complies □Does Not □Not Observable □Not Applicable	
C403.2.2 [FI27] ³	HVAC systems and equipment capacity does not exceed calculated loads.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.2.4. 1 [FI47] ³	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.2.4. 1 [FI47] ³	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.2.4. 1 [FI47] ³	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.4.1. 2 [FI38] ³	Thermostatic controls have a 5 °F deadband.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.2.4. 1.3 [FI20] ³	Temperature controls have setpoint overlap restrictions.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C403.2.4. 2 [FI39] ³	Each zone equipped with setback controls using automatic time clock or programmable control system.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
2.1,	Automatic Controls: Setback to 55°F (heat) and 85°F (cool); 7-day clock, 2- hour occupant override, 10-hour backup	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C403.2.4. 2.3 [FI41] ³	Systems include optimum start controls.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C408.1.1 [FI57] ¹	Building operations and maintenance documents will be provided to the owner. Documents will cover manufacturers' information, specifications, programming procedures and means of illustrating to owner how building, equipment and systems are intended to be installed, maintained, and operated.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	

Data filename: Z:\2020\20-047A - CDOT Rangely\ENG\Rangeley Comcheck.cck

Data filename: Z:\2020\20-047A - CDOT Rangely\ENG\Rangeley Comcheck.cck

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C408.2.1 [FI28] ¹	Commissioning plan developed by registered design professional or approved agency.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	
C408.2.3. 1 [FI31] ¹	HVAC equipment has been tested to ensure proper operation.	□Complies □Does Not □Not Observable □Not Applicable	
C408.2.3. 2 [FI10] ¹	HVAC control systems have been tested to ensure proper operation, calibration and adjustment of controls.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	
C408.2.4 [FI29] ¹	Preliminary commissioning report completed and certified by registered design professional or approved agency.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	
C408.2.5. 1 [FI7] ³	Furnished HVAC as-built drawings submitted within 90 days of system acceptance.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	
C408.2.5. 3 [FI43] ¹	An air and/or hydronic system balancing report is provided for HVAC systems.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	
C408.2.5. 4 [FI30] ¹	Final commissioning report due to building owner within 90 days of receipt of certificate of occupancy.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Data filename: Z:\2020\20-047A - CDOT Rangely\ENG\Rangeley Comcheck.cck

PASSION!

Report date: 08/07/20

Page 11 of 12

Transportation

of

Department

DRAWN BY: ASF DATE: 9/23/2020

> CDOT PROJECT NO. 17179